



**MIKE SPANO**  
MAYOR  
**ROBERT F. SWEENEY**  
COMMISSIONER

# CITY OF YONKERS

FIRE DEPARTMENT

470 NEPPERHAN AVENUE 2ND FLOOR

YONKERS, NEW YORK 10701

(914) 377-7500 FAX (914) 377-7560



## Photovoltaic System Installation Review Requirements

The following list shall represent the minimum documentation required for all photovoltaic system, including new systems and additions, or alterations to existing systems.

Please review and familiarize yourself with all requirements listed in this document prior to your submittal. Your compliance with these requirements will enable us complete the review process faster and more efficiently with less rejections due to improper submittals.

### **Solar photovoltaic power systems.**

Solar photovoltaic power systems shall be installed in accordance with this document, the New York State Building and Fire Codes and NFPA 70.

### **Marking.**

Marking is required on interior and exterior direct-current (DC) conduit, enclosures, raceways, cable assemblies, junction boxes, combiner boxes and disconnects.

### **Materials.**

The materials used for marking shall be reflective, weather resistant and suitable for the environment. Marking, as required by this document, shall have all letters capitalized with a minimum height of  $\frac{3}{8}$  inch white on red background.

### **Marking content.**

The marking shall contain the words "**WARNING: PHOTOVOLTAIC POWER SOURCE.**"

### **Main service disconnect.**

The marking shall be placed adjacent to the main service disconnect in a location clearly visible from the location where the disconnect is operated.

### **Location of marking.**

Marking shall be placed on interior and exterior DC conduit, raceways, enclosures and cable assemblies every 10 feet, within 1 foot of turns or bends and within 1 foot above and below penetrations of roof/ceiling assemblies, walls or barriers.

### **Locations of DC conductors.**

Conduit, wiring systems, and raceways for photovoltaic circuits shall be located as close as possible to the ridge or hip or valley and from the hip or valley as directly as possible to an outside wall to reduce trip hazards and maximize ventilation opportunities. Conduit runs between sub arrays and to DC combiner boxes shall be installed in a manner that minimizes the total amount of conduit on the roof by taking the shortest path from the array to the DC combiner box. The DC combiner boxes shall be located such that conduit runs are minimized in the pathways between arrays. DC wiring shall be installed in metallic conduit or raceways when located within enclosed spaces in a building. Conduit shall run along the bottom of load bearing members.

### **Access and pathways.**

Roof access, pathways, and spacing requirements shall be provided in accordance with the following requirements:

1. Residential structures shall be designed so that each photovoltaic array is no greater than 150 feet by 150 feet in either axis.
2. Panels/modules shall **NOT** be permitted to be located up to the roof ridge **EXCEPT** where an alternative ventilation method approved by the fire code official has been provided or where the *fire code official* has determined vertical ventilation techniques will not be employed.

### **Roof access points.**

Roof access points shall be located in areas that do not require the placement of ground ladders over openings such as windows or doors, and located at strong points of building construction in locations where the access point does not conflict with overhead obstructions such as tree limbs, wires, or signs.

### **Residential systems for one- and two-family dwellings.**

Access to residential systems for one- and two-family dwellings shall be provided in accordance with the following:

#### **Residential buildings with hip roof layouts.**

Panels/modules installed on residential buildings with hip roof layouts shall be located in a manner that provides a 3-foot-wide clear access pathway from the eave to the ridge on each roof slope where panels/modules are located. The access pathway shall be located at a structurally strong location on the building capable of supporting the live load of fire fighters accessing the roof.

**Exception:** These requirements shall not apply to roofs with slopes of two units vertical in 12 units horizontal (2:12) or less.

#### **Residential buildings with a single ridge.**

Panels/modules installed on residential buildings with a single ridge shall be located in a manner that provides two, 3-foot-wide access pathways from the eave to the ridge on each roof slope where panels/modules are located.

**Exception:** This requirement shall not apply to roofs with slopes of two units vertical in 12 units horizontal (2:12) or less.

**Residential buildings with roof hips and valleys.**

Panels/modules installed on residential buildings with roof hips and valleys shall be located no closer than 18 inches to a hip or a valley where panels/modules are to be placed on both sides of a hip or valley. Where panels are to be located on only one side of a hip or valley that is of equal length, the panels shall be permitted to be placed directly adjacent to the hip or valley.

**Exception:** These requirements shall not apply to roofs with slopes of two units vertical in 12 units horizontal (2:12) or less.

**Residential building smoke ventilation.**

Panels/modules installed on residential buildings shall be located no higher than 3 feet below the ridge in order to allow for fire department smoke ventilation operations.

**Other than one- and two- family dwellings.**

Access to systems for occupancies other than one- and two-family dwellings shall be provided in accordance with the following:

**Exception:** Where it is determined and approved by the *fire code official* that the roof configuration is similar to that of a one- or two-family dwelling, and installation will not hinder firefighting activities, the residential access and ventilation requirements shall be permitted to be used.

**Access.**

There shall be a minimum 6-foot-wide clear perimeter around the edges of the roof.

**Exception:** Where either axis of the building is 250 feet or less, there shall be a minimum 4-foot-wide clear perimeter around the edges of the roof.

**Pathways.**

The solar installation shall be designed to provide designated pathways. The pathways shall meet the following requirements:

1. The pathway shall be over areas capable of supporting the live load of fire fighters accessing the roof.
2. The centerline axis pathways shall be provided in both axes of the roof. Centerline axis pathways shall run where the roof structure is capable of supporting the live load of fire fighters accessing the roof.
3. Shall be a straight line not less than 4 feet clear to skylights or ventilation hatches.
4. Shall be a straight line not less than 4 feet clear to roof standpipes.

5. Shall provide not less than 4 feet clear around roof access hatch with at least one not less than 4 feet clear pathway to parapet or roof edge.

**Smoke ventilation.**

The solar installation shall be designed to meet the following requirements:

1. Arrays shall be no greater than 150 feet by 150 feet in distance in either axis in order to create opportunities for fire department smoke ventilation operations.
2. Smoke ventilation options between array sections shall be one of the following:
  - 2.1. A pathway 8 feet or greater in width.
  - 2.2. A 4-foot or greater in width pathway and bordering roof skylights or smoke and heat vents.
  - 2.3. A 4-foot or greater in width pathway and bordering 4-foot by 8-foot "venting cutouts" every 20 feet on alternating sides of the pathway.

**Ground-mounted photovoltaic arrays.**

Ground-mounted photovoltaic arrays shall comply with the requirements of this document for marking and DC conductor locations. Setback requirements shall apply to ground-mounted, free-standing photovoltaic arrays. A clear, brush-free area of 10 feet shall be required for ground-mounted photovoltaic arrays.